


NOTES

1. MINIMUM WIRE SIZE 18 AWG. FOR ALL COMMON CONDUCTORS AND 22 AWG. FOR ALL OTHERS.
2. REFER TO APPROPRIATE DATA SHEET FOR BACKBOX REQUIREMENTS. ALL BOXES TO BE U.L. LISTED.
3. USE GREEN CONDUCTOR FOR GROUND ONLY.
4. MAXIMUM CONTROL OUTPUT — 24 VDC 3 AMPS.

25 PAIR CABLE FURNISHED BY MANUFACTURER WITH CONNECTORS ON BOTH ENDS. REFER TO "NURSE STATION MASTERS" DATA SHEET FOR NECESSARY CABLE AND CONDUIT REQUIREMENTS.

CONTROL CABINET, FURNISHED TYPE 100-R20 24" H X 16" W X 4.5" D



MASTER

ENGINEERED ELECTRONICS INC.		DATE
P.O. BOX 60 — DOUGLASVILLE, GA. 30134		4-6-63
PROJECT FIELD WIRE CONNECTIONS		SCALE
VISUAL NURSE CALL SYSTEM		NONE
DRAWING		DWG BY
383-004		JJC
		SHEET
		1 of 1